

Home Energy Upgrade Advisory Report

BER No. 115506768

Your Home's Energy Performance Potential

NOW  POTENTIAL 



Potential with upgrades

Loss of heat from your home



NOW	POTENTIAL
Fair	Good

An upgrade package to **stop losing money** on your energy bill

Your BER assessor has recommended a package of upgrades that will raise your home's energy performance.

Energy Performance of your home

	NOW	POTENTIAL
Roofs	Poor	Good
Walls	Good	No Upgrade
Windows	Good	No Upgrade
Floor	Fair	No Upgrade
Space heating	Very Good	No Upgrade
Water heating	Very Good	No Upgrade
Renewables	Very Good	Very Good

GRANTS AVAILABLE?



subject to availability, terms and conditions

For further information visit www.seai.ie/grants or call 01 8082100

Compare your home's performance | Before and after upgrades

Your home's current energy performance	NOW B2	Your home's potential energy performance	POTENTIAL B1
---	-------------------------	---	-------------------------------

Benefits of upgrading your home

INCREASE your home's value



INCREASE your home's comfort



REDUCE your energy bills



SAVE

CO₂ | TONNES
1
= the same as planting **71 tree(s) each year**

To find out more visit www.seai.ie

Your journey from

BER B2

to

BER B1

Your BER assessor has recommended a package of energy upgrades that maximise the energy performance of your home. The recommendations are for guidance only and can be completed at your own discretion. The recommendations are just one potential pathway to an improved BER and it is open to you to discuss alternative packages with your professional advisors.

Package of energy upgrades to save money, make your home more comfortable and protect the environment

Recommended Package of Energy Upgrades	Cost (Approx.) ³	Grant Available ⁴	Comfort
External doors 1.4 W/m ² K average U-Value ^{1, 2}	€ € € €	✓	★ ★ ★ ☆ ☆
Roof insulation; pitched (at ceiling) 0.16 W/m ² K, pitched (on slope) 0.20 W/m ² K, room in roof (on side) 0.20 W/m ² K, flat 0.22 W/m ² K average U-Value ^{1, 2}	€ € € €	✓	★ ★ ★ ★ ☆
Space heating controls upgrade including time and temperature zone control	€ € € €	✓	★ ☆ ☆ ☆ ☆

1. Major Renovation is defined in the Building Regulations Part L Technical Guidance Document and means the renovation of a dwelling where more than 25 % of the surface of the dwelling envelope undergoes renovation. Where a dwelling undergoes a major renovation, the energy performance of the whole dwelling should be improved to the cost optimal level by achieving a B2 or by implementing the energy performance improvements as set out in the Building Regulations Part L Technical Guidance Document.
2. This energy upgrade will reduce your home's heat loss and is an important first step to improving the energy efficiency of your home.
3. Investment Cost Legend:
 - € < 5,000
 - €€ 5,000 - < 15,000
 - €€€ 15,000 - < 30,000
 - €€€€ 30,000 - 50,000
4. A grant for this type of upgrade is available at the time of publication of this report. Grant availability is subject to eligibility criteria and should be checked to see if the works to your own home meet the eligibility criteria. Eligibility criteria are subject to change.

GRANTS AVAILABLE?



subject to availability, terms and conditions

For further information visit
www.seai.ie/grants
 or call
 01 8082100

Start your journey to
upgrade your home

If you're not ready for the maximum SEAI grant, consider picking one or two energy upgrades, selecting areas with the poorest performance.



GRANT
APPLICATION

To start your application
today visit
www.seai.ie/grants

Potential impact of the **recommended energy upgrades**

Energy upgrade	Now		Potential	
	Value	Energy Efficiency	Value	Energy Efficiency
Home Heat Loss Indicator (HLI) ¹	2.537 W/(K·m ²)	Fair	2.233 W/(K·m ²)	Good
External doors (average U-Value ²)	3.000 W/m ² K	Poor	1.400 W/m ² K	Very Good
Roof insulation (average U-Value ²)	0.585 W/m ² K	Poor	0.151 W/m ² K	Good
Space heating controls upgrade including time and temperature zone control	Basic control	Fair	Advanced control	Good
Renewable Energy Ratio (RER)	29%	Very Good	35%	Very Good

1. The Home Heat Loss Indicator (HLI) is a summary of the overall performance of the home. It includes all the fabric and ventilation upgrades listed in the table
2. A U-value is a measure of the heat loss through the building fabric. The higher the U-value, the greater the heat loss
3. Primary energy efficiency is the efficiency divided by the primary energy conversion factor
4. Indicators are based on the average elemental U-values in the BER and where partial upgrades occur, average U-values may remain above the optimum U-value.

Home Energy Upgrade Advisory Report

Your Home's Details

Home Address

28 THE PADDOCKS NAAS CO. KILDARE, W91X5HR

House Details

Year of construction: 1977

Dwelling type: Detached house

Total floor area: 154.71 m²

About the Home Energy Upgrade Advisory Report

This document is a first step to assist you in engaging with a professional to determine suitable energy upgrades for your home.

It was prepared by a BER assessor using general assumptions and information from your BER assessment. The improvement in the BER has been estimated based on the assumption of certain values for energy upgrades and is provided as an indicator only.

This document is for information only and does not constitute professional or legal advice. The homeowner waives and releases any and all claims against SEAI and/or the BER assessor arising from the contents of this advisory report.

Use this document to:

Better understand how your home performs and how to make it more comfortable and affordable to run.

Provide information on home energy upgrades to discuss further with a professional or contractor.

Identify small simple steps you can take to improve the comfort of your home, if grant supported works aren't suitable for you right now.

Start the grant application process with SEAI, who may have substantial support available.

Recommended Energy Upgrades

The recommendations contained within your advisory report have been generated based on the data inputs contained within your BER assessment. SEAI recommends you seek professional advice and use suitably qualified installers to assess the suitability of the recommendations for your own particular home.

SEAI and the BER assessor accept no responsibility for and give no guarantees, undertakings or warranties concerning the accuracy, completeness or fitness-for-purpose of the information contained herein and do not accept any liability whatsoever arising from the contents hereof.

Further information on upgrading your home is available in **S.R. 54:2014 Code of Practice for the Energy Efficient Retrofit of Dwellings**, available from www.nsai.ie.

Building Regulations

The aim of the building regulations is to provide for the safety and welfare of people in and about buildings. Where applicable, works should be completed in accordance with the relevant Building Regulations. The primary responsibility for compliance with the requirements of the Building Regulations rests with the designers, builders and owners of buildings. Technical Guidance Documents for the Building Regulations and other supporting documents are available from the Department of Housing, Local Government and Heritage website at www.housing.gov.ie.

Costs

The investment cost indicators are guidelines only. Actual costs will vary depending on house size, specification and market conditions. Cost indicators may be calculated based on a partial upgrade if some sections of the building element are already adequately insulated.

Please consider the environment before printing this document.

BER Privacy Notice: www.seai.ie/publications/BER-Privacy-Notice.pdf

Ventilation

Care should always be taken to ensure sufficient levels of ventilation in each room. Signs of inadequate ventilation are persistent condensation and mould growth and should be addressed in the first instance. It is important not to permanently close or cover over air vents as they are required to provide ventilation. Further guidance on ventilation provision when carrying out retrofit works is available in Section 10 Ventilation of S.R. 54:2014 Code of Practice for the Energy Efficient Retrofit of Dwellings.

Radon

Radon gas at high concentration causes lung cancer and is estimated to be responsible for 300 cases per annum in Ireland. Retrofitting provides an opportunity to test for, and remediate for, radon, where indicated. A radon test is low cost and non-disruptive. The only way to know if a home has a radon issue is to test. Further information on radon, including testing, is available on the EPA website www.epa.ie.

Heat producing Appliances

It is important to ensure that there is an adequate air supply to all heat producing appliances e.g. any fixed appliance (including a cooker or an open fire) which is designed to burn solid fuel, oil, bio-fuel or gas and to provide permanent ventilation for all non-room sealed combustion appliances. Useful health and safety information can be found on the Carbon Monoxide safety website: www.carbonmonoxide.ie. Further guidance on air supply for heat producing appliances is available in Section 7 and Section 10 Ventilation of S.R. 54:2014 Code of Practice for the Energy Efficient Retrofit of Dwellings.

Evidence for BER

Documentary evidence of energy upgrades is required for your BER and should be retained and provided to your BER assessor to ensure the energy performance uplift is captured in your BER. Your BER Assessor can advise you on documentary evidence requirements. Further information is available on <https://www.seai.ie/home-energy/building-energy-rating-ber/>.