



SITE PLAN 1:150



FOUL DRAINS 1000 UPVC AT MINIMUM GRADIENT OF 1 in 60 EXCEPT WHERE SHOWN OTHERWISE. STORM DRAINS ALL 1000 UPVC AT MINIMUM GRADIENTS OF 1 in 80.

ALL WORKMANSHIP AND MATERIALS TO BE IN ACCORDANCE WITH RECOMMENDATIONS FOR SITE DEVELOPMENT WORKS FOR HOUSING AREAS AS PUBLISHED BY THE DEPARTMENT OF THE ENVIRONMENT AND WITH THE GREATER DUBLIN REGIONAL CODE OF PRACTICE FOR DRAINAGE WORKS

REV	DATE	DESCRIPTION	ARCHITECT	SCALE	PROJECT	JOB NO.
			FRANK ELMES	1:150	PROPOSED HOUSING AT LIFFEY STREET SOUTH DUBLIN 10	FE016
			ISSUED FOR	TECHNICIAN	TITLE	DATE
			PLANNING	MF	SITE DRAINAGE & FINISHED LEVELS	August 2017
				ENGINEER		DRAWING NO.
				TS		01
			© COPYRIGHT GLENN NUNAN CONSULTING ENGINEERS	ORIGINAL SIZE A1	GNCE Glenn Nunan Consulting Engineers	